

**REGIONAL WATER TESTING LAB, AMRITSAR**  
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.  
rwtlasr1@gmail.com

To,

SKS International School Amritsar  
SKS International School Amritsar Maure Khurd Near Lopoke Chogawan Amritsar


No.: RWTLASR/2324/00009 Dated : 21/04/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SKS/181/2023-24 Dated: 12/04/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 17/04/2023. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



**Authorized Signatory**  
For, Regional Water Testing Lab, Amritsar

**REGIONAL WATER TESTING LAB, AMRITSAR**  
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.  
rwtlasr1@gmail.com



TC-9815

**TEST REPORT**

Name & Address of Customer : <b>SKS International School Amritsar</b> <b>SKS International School Amritsar Maure Khurd</b> <b>Near Lopoke Chogawan Amritsar</b>	Customer Reference No.	<b>No : SKS/181/2023-24 Dated : 12/04/2023</b>
	Sample Submitted by	<b>Mr. Raj Kumar</b>
	Date of Sample Receipt	<b>17/04/2023</b>
	Analysis Starting Date	<b>17/04/2023</b>
	Analysis completion Date	<b>18/04/2023</b>

Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
ULR No.:	<b>TC981523000000213F</b>	Sample Type :	<b>Water</b>
Test Report No.:	<b>RWTLASR/2324/00009</b>	Date of Issue :	<b>21/04/2023</b>
Registration no.:	<b>RWTLASR/REG2324/00298</b>	Condition of Sample :	<b>Unsealed</b>
Collection Point:	<b>Private Submersible</b>	Quantity/Type of Bottle:	<b>1000 ml / Plastic Bottles</b>
Scheme/Source:	<b>Not Mentioned(Not Mentioned)</b>	Location/Depth :	<b>Near Lopoke Chogawan(S/pump 350 ft) / NA</b>
Village :	<b>Not Mentioned</b>	Habitation :	<b>Not Mentioned</b>
Block:	<b>Not Mentioned</b>	District :	<b>Amritsar</b>
Latitude :	<b>Not Mentioned</b>	Longitude:	<b>Not Mentioned</b>

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.45	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993 ) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	267	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.35	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	252	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	204	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	36.87	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	27.21	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	17.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

*Shivani Singh*  
**Principal**  
**SKS International School**  
**Maure Khurd, Near Lopoke**  
**Chogawa, (Amritsar)**

*Pankaj Kumar*

**Mr. Pankaj Kumar**  
**Quality Manager**  
**Authorized Signatory**  
**For,Regional Water Testing Lab, Amritsar**

----- End of the Test Report -----