

Executive Engineer, Central Works Division No.2,

Public Works Department (B&R) Br., Batala Road, Amritsar

E-mail:- xencw2amritsar@gmail.com

To

Principal
SKS international School,
V.P.O Maure Khurd ,Near Lopoke Chogawana.
Distt. Amritsar

No. 1088



Dated: 11/7/24

Subject: Building Safety Certificate for the year 2024-2025.
(SKS international School V.P.O Maure Khurd ,Near Lopoke Chogawana,
Distt.Amritsar.)

Reference: Your office letter No. NILL dated:NILL.

Sub Divisional Engineer, Provincial Sub Division No.4, P.W.D. (B&R) Br., Amritsar vide his letter No. 51 dated: 03.07.2024 has reported this office that the building of " SKS international School V.P.O Maure Khurd ,Near Lopoke Chogawana, Distt.Amritsar " has been visually inspected and found the same provisionally fit for human inhabitation for the year 2024-25 i.e. upto 31.03.2025. Your application for safety certificate will only be considered when you will fulfill all requirement under column 14 of Performa Part-I.

DA/Performa I & II




Executive Engineer,
Central Works Division No.2,
P.W.D. (B&R) Br., Amritsar.

~~Endst.No.~~ _____

Dated: _____

A copy of above is forwarded to Sub Divisional Engineer, Provincial Sub Division No.4, P.W.D. (B&R) Br., Amritsar w.r.t. his letter No. 51 dated: 03.07.2024 for information and necessary action.

D.A./Nil


Executive Engineer,
Central Works Division No.2,
P.W.D. (B&R) Br., Amritsar.

- b) Terrace
- c) Brick Paving

Yes/No
Yes/No

12. A detailed drawing indicating the doors along with windows and location fitting and windows is attached.

13. FOR FIRE SAFETY

- a) Whether the width of the staircase is 1.5 mtr.
- b) Whether portable fire extinguisher exists
- c) Whether School building is free from inflammable & toxic material
- d) Whether cooking of food is done at a safe place
- e) Whether any Thatch or combustible material has been used

Yes/No
Yes/No
Yes/No
Yes/No
Yes/No

14. Requirement for Fire Protection Arrangements under NB-Part-IV (For Building height less than 15 metre)

- a) Whether Hose Reel provided
- b) Whether down comer provided
- c) Whether Automatic sprinkler provided
- d) Whether underground static water storage tank of capacity 50000 Ltr. (if converted area exceeds 1500 sqm)
- e) Whether over head tank of capacity 10000 Ltr. exists (in case of hose reel) 20000 Ltr.
- f) Whether one electric and one diesel pump of 3 kg/cum Pressure of capacity 1620 LPM, one electric pump of Capacity 180 LPM exist near underground static tank.
- g) Whether a pump 3 kg/cum pressure & 450-500 LPM Exist near over head tank.

Yes/No
Yes/No
Yes/No
Yes/No
Yes/No
Yes/No
Yes/No

Shivani Singh
Principal
Signature of the Head of School/
SKS International School
Maure Khurd, Near Lopoke

PART-II Chogawa, (Amritsar)

(To be filled by the SDE of PWD (B&R) Department)

- a) I have visited the above mentioned school on dated 25/06/2024 and have visually inspected it from all angles of safety and find it fit for normal use as school building.
- b) In case any addition/alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) 31/03/2025

Shivani Singh
Principal
SKS International School
Maure Khurd, Near Lopoke
Chogawa, (Amritsar)

[Signature]
Sub Divisional Engineer,
Provincial Sub Division No. 4,
PWD B&R Br., Amritsar.