

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal SKS International School
V.P.O Maure Khurd, Near Lopoke, Chogawan

No.: RWTLASR/2425/01668 Dated : 29/03/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SKS/298/2024-25 Dated: 21/03/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 22/03/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com



TC-13602

TEST REPORT

Name & Address of Customer : Principal SKS International School V.P.O Maure Khurd, Near Lopoke, Chogawan			Customer Reference No.	No : SKS/298/2024-25 Dated : 21/03/2025		
			Sample Submitted by	Mr. Kirandeep Singh		
			Date of Sample Receipt	22/03/2025		
			Analysis Starting Date	24/03/2025		
			Analysis completion Date	25/03/2025		
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC136022500000211F		Sample Type :	Water		
Test Report No.:	RWTLASR/2425/01668		Date of Issue :	29/03/2025		
Registration no.:	RWTLASR/REG2425/14622		Condition of Sample :	Unsealed		
Collection Point:	Private Submersible		Quantity/Type of Bottle:	1000 ml / Plastic Bottles		
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :	Maure Khurd(S/pump 350 ft) / NA		
Village :	Not Mentioned		Habitation :	Not Mentioned		
Block:	Not Mentioned		District :	Amritsar		
Latitude :	Not Mentioned		Longitude:	Not Mentioned		
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.79@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	311	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.75@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	260	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	232	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	46.49	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	28.18	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	29.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pardeep Kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Amritsar

----- End of the Test Report -----